

12/13/2017

ADDENDUM NO. 1
TO THE BID DOCUMENTS
(construction plans and bid package)
FOR THE
FRIENDSHIP FOREST WILDLIFE SANCTUARY
PARK RENOVATION PROJECT

Questions Received:

1. Is this a unit price bid?
2. How will un-suitables be handled?
3. Is there a geotechnical report?
4. Will the owner employ a third party for all inspections and special inspections?
5. If it is unit price, how will export be measured

Response to Questions:

1. **Yes**
2. **All unsuitables will be placed on site at various locations within the park. The city will identify these locations; i.e. examples of areas for placement include shoulders, where asphalt trails are removed, etc. This includes all soil excavated in the wetlands area**
3. **No. Rock does not exist within the project limits. Soil types within the wetlands area are included in the plans**
4. **Yes**
5. **Minimal or no soil to be exported. A pay item exists for "Soil Haul Off". Costs for removal of other waste (tree/brush removal) is to be included in the "Site Demolition" pay item**