



ADVERTISEMENT for CONSTRUCTION SERVICE

ITB - PEDESTRIAN IMPROVEMENT PROJECTS - 122324

ADDENDUM No. 5

OWNER'S BID PROPOSAL FORM

OWNER: City of Clarkston
1055 Rowland Street
Clarkston, GA 30021

PROJECT: Pedestrian Improvement Projects

DATE: December 11, 2024

BID #122324 is hereby revised as instructed throughout attached ADDENDUM No. 5.

This Addendum forms a part of the contract documents and modifies the original bid documents. The following items shall take precedence over the originally published bid documents for the above-named project and shall become a part of the contract documents.

BidNet questions and responses (Q8 – Q14)

1. Are there any MBE or DBE requirements for this project or is it just highly suggested?
 - a. **A 5% DBE goal is required by the City.**
2. Do we have 60 calendar days to complete both project #1 and #2 or is it 60 calendar days for each project?
 - a. **A total of 60 calendar days for the entire project.**
3. The Attachment B (Exhibit R) of the Site Furniture shows a Decorative Fence, please confirm if this would be included and the quantity required.
 - a. **Decorative fence shall not be included in the Bid Schedule of Items. It's not included in the project scope.**
4. Please clarify location of plain concrete item.
 - a. **The 10 ft. x 10 ft. concrete slab is for each of the bench and trash container locations.**
5. In front of the Police department is the driveway apron 6 in depth? and how far back are we going with the apron?
 - a. **No – 8 inch thickness. The dimensions of the driveway apron will be 20 ft. wide and length of 10 ft.**
6. With question 12, how wide is that apron going to be?
 - a. **The entrance dimensions for the Clarkston Woman's Club area are reflected in the diagrams located in the ITB. The thickness of each driveway will also be 8 inches.**

7. Are we bidding the project as two separate projects or are we bidding it as one whole project?
 - a. One project. Quantities for both projects are all in one Schedule of Bid Items (Cost Proposal)
8. See revised Bid Schedule of Items Form & Cost of Proposal (Adden 5) for updated Item No. 441-0018 quantity change.